



**COMPOSITION OF NITROGEN
COMPOUNDS IN WASTE TO
ENERGY EMISSIONS**

APPENDIX

17

APPENDIX 17: Composition of Nitrogen Compounds in Waste to Energy Emissions

Memo

Hitachi Zosen Inova AG
Hardturmstrasse 127
CH-8005 Zürich
Switzerland

Ruedi Frey
FGT / Senior Engineer
Phone +41 44 277 12 66

ruedi.frey@hz-inova.com

www.hz-inova.com

Composition of Nitrogen compounds in WtE-Emissions7 September 2017

Background and Introduction

In all Waste-to-Energy plants, NO_x emissions are limited. Common (EU) Emission Limit Value (ELV) is 200 mg/m³_N @ 11% O₂ dry.

In many plants, NO_x is measured as NO and calculated to NO_x since NO₂ percentage is normally low.

NO_x is often controlled by Ammonia water injection into the Post Combustion Chamber (SNCR process), so a certain Ammonia slip (not limited in EU-Regulation) occurs.

Furthermore, as a by-product of combustion or denitrification process, nitrous oxide may be released (not limited by EU regulation, but in focus since it is a strong greenhouse gas)

In one UK plant at two lines, all of the possible nitrogen components are measured continuously. The plant controls NO_x by SNCR (Ammonia water injection) and other pollutions with a lime-based semi-dry FGT (presumption: no or only minor influence on nitrogen compounds).

The plant was commissioned 2013 and is in normal operation. CEMS data are available to HZI by daily data transfer called "Pamela".

Results

Data from the year 2016 have been evaluated as daily average values. Days where the plant was out of service or in transition (start-up / stop mode) have been cut out. The number of evaluated days (plant in normal operation), the average value (= yearly average value), a calculated standard deviation as well as the minimum and maximum values are represented in the following table.

The values are given in ppm but are already referred to 11% O₂ dry.

UK plant Line 4							
		NO ppm	NO ₂ ppm	NOx ppm	percentage NO ₂ %	N ₂ O ppm	NH ₃ ppm
number of values	(days)	343	343	343	343	343	343
Average	(yearly)	93.8	0.8	94.6	0.9%	2.2	2.6
Standard deviation		7.0	0.7	6.5	1.2%	0.6	0.9
Minimum value		49.1	0.1	56.4	0.1%	1.9	0.5
Maximum value		105.2	7.3	105.8	12.9%	11.0	5.8
UK plant Line 5							
		NO ppm	NO ₂ ppm	NOx ppm	percentage NO ₂ %	N ₂ O ppm	NH ₃ ppm
number of values	(days)	342	342	342	342	342	342
Average	(yearly)	97.3	0.5	97.9	0.6%	1.7	4.1
Standard deviation		4.5	0.3	4.4	0.4%	0.3	2.5
Minimum value		56.6	0.0	58.4	0.0%	2.1	0.7
Maximum value		102.8	4.3	103.2	6.0%	5.7	15.0

Conclusion:

Percentage NO₂ of total NOx is less than 1%. It is useless to measure continuously NO₂ – better to put the set point of the NOx-controller 1% lower.

Nitrous oxide emissions are at low level, effort for continuous measurement is not justified.

Note that this data show – according to the table above – some daily NOx values exceeding the limit of 200 mg/m³_N @ 11% O₂ dry (conversion factor ppm to mg/m³ = 2.0525) – but according to EU regulation, NOx measurement has an uncertainty of 20%.

This 20% is deducted from the measured/calculated values (common practice in Europe), therefore all daily average values from both lines fulfil the legal requirements.